


Eastern Analytical Services, Inc.

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - Ardsley High School

Date Collected: 11/16/2016
Collected By: Ernest Coon
Date Received: 11/16/2016
Date Analyzed: 11/17/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
1 2466014	Small Gym - Water Fountain	Water	BDL < 0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis


Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - Concord Road Elementary

Date Collected: 11/16/2016
Collected By: Ernest Coon
Date Received: 11/16/2016
Date Analyzed: 11/17/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
1 2466012	Fountain Between Rooms 3 & 5	Water	0.002 mg/L
2 2466013	Fountain Near Library	Water	BDL < 0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis


Results Applicable to Those Items Tested

AJHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Water Sample Report

RE: CPN ARD-1109-16-IH - Ardsley CSD

Date Collected: 10/01/2016
Collected By: S. Coon
Date Received: 10/04/2016
Date Analyzed: 10/11/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
A-1 2457662	New Water Fountain - 3rd Grade Wing	Water	0.001 mg/L
A-2 2457663	L3 Sink	Water	0.027 mg/L
A-3 2457664	L3 Water Fountain	Water	0.118 mg/L
A-4 2457665	Not Applicable	Water Blank	BDL < 0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis


Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Water Sample Report

RE: CPN ARD-1109-16-1H - Ardsley UFSD - Concord Road & Middle School

Date Collected: 09/17/2016
Collected By: Ernest Coon
Date Received: 09/17/2016
Date Analyzed: 09/22/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
1 2452055	Nurses Office - Sink #1 (From Left to Right) - Middle School	Water	0.002 mg/L
2 2452056	Nurses Office - Sink #2 (From Left to Right) - Middle School	Water	0.001 mg/L
3 2452057	Library Main Lab - Sink (From Left to Right) - Middle School	Water	0.005 mg/L
4 2452058	Classroom #1 - Sink - Concord Road School	Water	0.031 mg/L
5 2452059	Classroom #2 - Sink - Concord Road School	Water	0.037 mg/L
6 2452060	Classroom #4 - Sink - Concord Road School	Water	0.760 mg/L
8 2452062	P1A Faculty Lounge - Sink - Concord Road School	Water	0.265 mg/L
9 2452063	P1A Faculty Lounge - Water Fountain - Concord Road School	Water	0.373 mg/L
10 2452064	Not Applicable	Water Blank	0.004 mg/L

BDL = Below Detectable Limits


Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.
Water Sample Report

RE: CPN RD-1083-16-IH - Concord Road School

Date Collected: 06/29/2016
Collected By: Nick Coon
Date Received: 06/30/2016
Date Analyzed: 07/07/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
1A 2434790	CR 2 Sink	Water	0.022 mg/L
1B 2434791	CR 2 Sink	Water	0.004 mg/L
2A 2434792	CR 1 Sink	Water	0.032 mg/L
2B 2434793	CR 1 Sink	Water	0.004 mg/L
3A 2434794	Water Fountain Between CR 1 & 2	Water	0.042 mg/L
3B 2434795	Water Fountain Between CR 1 & 2	Water	0.012 mg/L
4A 2434796	CR 4 Sink	Water	0.096 mg/L
4B 2434797	CR 4 Sink	Water	0.032 mg/L
5A 2434798	Water Fountain Between CR 4 & 6	Water	0.050 mg/L

BDL = Below Detectable Limits


Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.
Water Sample Report

RE: CPN RD-1083-16-IH - Concord Road School


Date Collected: 06/29/2016
Collected By: Nick Coon
Date Received: 06/30/2016
Date Analyzed: 07/07/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
5B 2434799	Water Fountain Between CR 4 & 6	Water	0.029 mg/L
6A 2434800	Water Fountain Between CR 8 & 10	Water	0.301 mg/L
6B 2434801	Water Fountain Between CR 8 & 10	Water	0.358 mg/L
7A 2434802	Water Fountain Near CR 31	Water	0.018 mg/L
7B 2434803	Water Fountain Near CR 31	Water	0.002 mg/L
8A 2434804	Water Fountain Near CR 35	Water	0.022 mg/L
8B 2434805	Water Fountain Near CR 35	Water	0.004 mg/L
9A 2434806	CR L3 Water Fountain	Water	0.002 mg/L
9B 2434807	CR L3 Water Fountain	Water	0.001 mg/L

Eastern Analytical Services, Inc.
Water Sample Report

RE: CPN RD-1083-16-IH - Concord Road School


Date Collected: 06/29/2016
Collected By: Nick Coon
Date Received: 06/30/2016
Date Analyzed: 07/07/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
10A 2434808	Primary Faculty Room Water Fountain	Water	0.046 mg/L
10B 2434809	Primary Faculty Room Water Fountain	Water	0.011 mg/L
Blank 2434810	Not Applicable	Water Blank	BDL < 0.001 mg/L

Eastern Analytical Services, Inc.
Water Sample Report

RE: CPN RD-1083-16-IH - Ardsley Middle School

Date Collected: 06/29/2016
Collected By: Nick Coon
Date Received: 06/30/2016
Date Analyzed: 07/07/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
1A 2434735	Library Mac. Room Sink	Water	0.049 mg/L
1B 2434736	Library Mac. Room Sink	Water	0.007 mg/L
2A 2434737	Nurses Sink #1 (From Left to Right)	Water	0.006 mg/L
2B 2434738	Nurses Sink #1 (From Left to Right)	Water	0.003 mg/L
3A 2434739	Nurses Sink #2 (From Left to Right)	Water	0.023 mg/L
3B 2434740	Nurses Sink #2 (From Left to Right)	Water	0.002 mg/L
Blank 2434741	Not Applicable	Water Blank	BDL < 0.001 mg/L